Lateral Tuning in Crack and Plug



Simulation Group Meeting Apr 20th, 2006

Introduction



Leakage effects introduce interdependence between lateral profile and absolute E/p tuning.

Limited geometrical acceptance due to signal definition:

- Plug: EM: 2x2, HAD: 3x3

- Crack: EM: 3x1, HAD: 3x1

Cannot expand signal region.

See my SGM talk of 04/06/06 for more details.


 Seperate lateral tuning for different calorimeter parts might thus become necessary.

This talk:


- Lateral profile tuning update in the Plug
- First tuning steps in Crack region (target towers 10+11)
- Leakage correction

Central and Plug







Crack: Tower 11




- First "low resolution" look using already existing samples (by-product from plug scan)
- Suffers from too low MC stats of tune samples!
- Tune method seems to work also here.




Tower 11 Profiles



Crack: Tower 10



Too poor tune sample stats, no chance to make reasonable contraint along Y axis ...




Leakage Correction

- For absolute E/p tuning we probably need a correction for remaining imperfectness of simulated lateral profiles.
- Plug: Use target towers with well contained signal and leakage regions.

EM: (13) 14,15 HAD: 14,15

Method:

- 1) Correct for background
- 2) Calculate leakage fraction: f = S/(S+L)S=signal, L=leakage (adjacent towers in η)
- 3) Leakage correction: k=f(Data)/f(MC)
- 4) For tuning of FEDP/sampling fractions, use $\langle E/p \rangle^{cor} (p) = k(p) \langle E/p \rangle (p)$ (for EM and HAD)
- NB: k(p)supposed to cope with pure lateral details.
 Not sure if we can apply such a procedure to crack towers because of the inhomogenity of adjacent towers (effect might be different in MC and data).





X extrapolated track impact point

Next Steps...



- Need to enlarge MC statistics for Crack region.
- New CAF attack with FAKE_EV but no minbias on top:
 - uncorrelated background not crucial for lateral profile
 - speeds up brute force parameter scan significantly
- With increasing precision it might be useful to introduce separate parametrization for Plug and Crack towers.
- Hope to derive final tune for Plug and Crack within next 1-2 weeks.
- Will re-evaluate profiles based on new parameters.
- Derive leackage corrections for remaining MC/data mismatch.